

Pumps


Centrifugal and Positive Displacement Pumps

Pumps are mechanical devices designed to transfer liquids from a location of low elevation or low pressure to a higher elevation or higher pressure zone by converting mechanical energy into hydraulic energy. Broadly categorized based on how they impart energy to the fluid, pumps are divided into two primary classifications: **Dynamic (or Kinetic) pumps** and **Positive Displacement pumps**.

Classification of Pumps

1. Dynamic or Kinetic Pumps

Dynamic pumps are types of pumps in which mechanical energy is continuously added to the fluid, primarily to increase its velocity (kinetic energy). This high-velocity fluid is subsequently directed into an expanding casing (volute) where the velocity decreases, successfully converting kinetic energy into pressure energy.




Centrifugal Pump

- **Centrifugal Pumps:** The most common dynamic pump, utilizing a rotating impeller to fling fluid outward via centrifugal force.
- **Jet Pumps:** Pumps that use a high-pressure nozzle to create a high-velocity jet, inducing suction to move surrounding fluid.
- **Turbine Pumps:** High-pressure pumps utilizing a specialized impeller with numerous small vanes rotating in an annular channel to build fluid velocity and pressure.

2. Positive Displacement Pumps

Positive displacement pumps are types of pumps in which mechanical energy is continuously added to the fluid by the direct application of force to a periodically enclosed volume. As the internal volume decreases, it forces the fluid out of the discharge port, resulting in a direct increase in its pressure. Unlike dynamic pumps, their flow rate is relatively constant regardless of changes in discharge pressure.



Reciprocating Pump

- **Reciprocating Pumps:** Rely on a back-and-forth movement of a piston, plunger, or plunger mechanism to draw fluid in and push it out through check valves.
- **Rotary Pumps:** Use interlocking gears, screws, or lobes that rotate to trap a fixed volume of fluid and move it from the suction side to the discharge side.
- **Diaphragm Pumps:** Utilize a flexible membrane (diaphragm) that expands and contracts to alter the volume of the pump chamber, drawing in and expelling fluid.

CENTRIFUGAL PUMPS

Centrifugal pumps are highly favored in industrial applications due to their operational efficiency at high speeds, but they carry distinct operational characteristics that must be managed.

Advantages

- **Simple and Compact Design:** Centrifugal pumps feature very few moving parts—principally just the impeller and the shaft. This lack of complex internal mechanisms reduces their physical footprint, making them highly space-efficient and cost-effective to manufacture.
- **Easy to Maintain:** Because of their mechanical simplicity and the absence of complex reciprocating linkages or internal valves, routine maintenance, parts replacement, and troubleshooting are straightforward.
- **Adaptability to High RPM Motors:** They can be directly coupled to high-speed electric motors or internal combustion engines operating at high revolutions per minute (RPM). This direct coupling eliminates the need for expensive speed-reducing gearboxes.

Disadvantages & Operational Challenges

- **Poor Suction Power:** Unlike positive displacement pumps, centrifugal pumps are generally incapable of creating a strong initial vacuum to draw fluid upward from a lower level when the suction line contains air.
- **Usually Needs Priming:** Because of their poor air-handling capability, centrifugal pumps must undergo **priming** prior to startup. Priming is the process of completely filling the pump casing and suction piping with the liquid to be pumped, displacing any trapped air or gas. If air is present, the impeller cannot generate the centrifugal force required to lift and move the fluid, causing the pump to become air-bound.

- **Cavitation may Develop During Operation:** Cavitation is a highly destructive phenomenon that occurs when the local pressure inside the pump drops below the vapor pressure of the liquid being pumped. When this happens, the liquid boils locally, forming vapor bubbles. As these bubbles move into regions of higher pressure within the impeller, they collapse or implode violently. These microscopic implosions generate extreme localized shockwaves that can pit and erode the metal surfaces of the impeller and casing, cause severe vibrations, degrade efficiency, and ultimately lead to mechanical failure.

Water or Hydraulic Power (WP)

In fluid mechanics and hydraulic machinery, **Water Power (WP)**, also referred to as **Hydraulic Power**, represents the theoretical energy per unit time added by the pump's impeller to the water or fluid as it moves through the pump assembly. It constitutes the net useful power transferred directly to the liquid medium to overcome elevation changes, friction, and pressure differentials in a piping system.

The Governing Power Equations

Depending on whether the fluid flow rate is measured volumetrically or by mass, water power can be calculated using two primary mathematical models.

1. Volumetric Flow Rate Approach

When the pump capacity is given as a volume flow rate, the fundamental equation for water power is expressed as:

$$WP = Q\gamma_w TDH$$

Where:

- **WP** = Water or hydraulic power, typically expressed in kilowatts (kW) or horsepower (hp). To convert between these power units, the standard conversion factor is:
 $1 \text{ hp} = 0.746 \text{ kW}$.
- **Q (V)** = Pump capacity or volume flow rate, measured in cubic meters per second (m^3/s).
- γ_w = Specific weight of the water or fluid.
- **TDH** = Total Dynamic Head, representing the total equivalent height the fluid is raised, measured in meters (m) or feet (ft).

2. Mass Flow Rate Approach

To account for gravitational acceleration variants and mass metrics, the specific weight γ_w can be defined using the fluid density ρ_w , local gravitational acceleration g_o , and the gravitational dimensional constant g_c :

$$\gamma_w = \rho_w \left[\frac{g_o}{g_c} \right] = \frac{m_w}{V_w} \left[\frac{g_o}{g_c} \right]$$

By substituting this physical definition back into the volumetric power formula, the equation simplifies to a mass flow rate configuration:

$$WP = m_w \left[\frac{g_o}{g_c} \right] TDH$$

Where:

- m_w = Mass flow rate of the water or fluid, quantified in kilograms per second (kg/s) or pounds-mass per second (lb_m/sec).
- g_o/g_c = The dimensionless conversion or gravitational proportionality ratio ensuring unit consistency across SI and English engineering systems.

Fluid Physical Properties at Standard Conditions

For calculation consistency in board examinations, the specific weight of water (γ_w) is conventionally evaluated at standard atmospheric conditions and a temperature of 4°C (where water reaches its maximum density).

- **International System of Units (SI):** $\gamma_w = 9.81 \frac{kN}{m^3}$
- **English Engineering System:** $\gamma_w = 62.4 \frac{lbm}{ft^3}$

The **Total Dynamic Head (TDH)**, conventionally referred to as the **pump head**, is a core hydraulic parameter representing the total amount of useful work required by a pump per specific weight of the water or fluid flowing through the system. Commonly measured in units of length, such as meters (m) or feet (ft), TDH characterizes the system's net resistance that the pump must overcome to move a fluid from one point to another. Mathematically and physically, it is defined as the cumulative sum of four distinct components:

By defining the system boundary from the suction source (State 1) to the final discharge point (State 2), the total energy balance equation incorporates potential energy (PE), kinetic energy (KE), flow work (Wf), internal energy (U), and the mechanical energy input from the pump, known as Water Power (WP). Setting up the balance yields:

$$PE_1 + KE_1 + Wf_1 + U_1 + WP = PE_2 + KE_2 + Wf_2 + U_2$$

Rearranging this expression to isolate the net useful energy added by the pump (WP) results in a grouping of differential energy terms:

$$WP = (PE_2 - PE_1) + (KE_2 - KE_1) + (Wf_2 - Wf_1) + (U_2 - U_1)$$

Key Operational Assumptions and Simplifications

To transform this fundamental thermodynamic equation into standard hydraulic head calculations for practical engineering applications, several critical assumptions are applied based on normal operating conditions:

1. Isothermal Flow and Internal Energy Simplification ($\Delta U \approx 0$)


In typical water-pumping applications, if we assume that the temperature of the fluid at the suction inlet (t_1) and the discharge outlet (t_2) are approximately equal ($t_1 \approx t_2$), the fluid experiences an isothermal process. Because internal energy for incompressible liquids is primarily a function of temperature, any change in internal energy across the pump is negligible. Therefore, the internal energy terms cancel out of the equation: $\Delta U = U_2 - U_1 \approx 0$

2. Steady State Incompressible Flow ($V_1 \approx V_2$)

We can also assume a steady-state pumping process for the system. For an incompressible fluid like water operating under normal pressure limits, the volumetric flow rate entering the suction side (V_1) is equal to the volumetric flow rate exiting the discharge side (V_2). This permits a constant density and specific weight profile throughout the evaluation.

Suction Lift

The system schematic illustrates a **Suction Lift** configuration, which is a specific arrangement where the pump centerline is positioned *above* the liquid level of the suction reservoir.



Total Dynamic Head (TDH):

$$TDH = (z_2 + z_1) + \frac{v_2^2 - v_1^2}{2g_o} + \frac{P_2 - P_1}{\gamma_w}$$

Incorporating Real-World Piping Losses

In real engineering applications, energy is continuously dissipated due to fluid friction against internal pipe walls and turbulent disruptions through elbows, valves, and various fittings. To account for these irreversibilities, a head loss term (h_L) must be appended to the ideal system balance:

$$TDH = (z_2 + z_1) + \frac{v_2^2 - v_1^2}{2g_o} + \frac{P_2 - P_1}{\gamma_w} + h_L$$

This yields the complete engineering design formula:

$$TDH = (\text{total static head}) + (\text{velocity head}) + (\text{pressure head}) + (\text{friction loss})$$


In shorthand notation, this is conventionally written as:

$$TDH = h_s + h_v + h_p + h_L$$

Total Static Head (h_s)

The **total static head** is the absolute vertical distance through which a pump must lift a liquid. It is measured continuously from the free water surface level of the source supply to the ultimate point of discharge. Depending on the physical elevation of the supply source relative to the pump's physical centerline, the suction side configuration is classified in one of two ways:

- **Static Suction Lift:** This condition occurs when the supply water source surface is located **below** the pump centerline. In this arrangement, the pump must exert negative pressure (vacuum) to pull the water up to the impeller. $h_s = z_2 + z_1$
- **Static Suction Head:** This condition occurs when the supply water source is located **above** the pump centerline. Under a static suction head arrangement, gravity naturally forces the fluid down into the pump inlet, providing a positive pressure assist at the suction eye. $h_s = z_2 - z_1$



Velocity Head (h_v)

The **velocity head** represents the energy possessed by the fluid solely due to its kinetic movement and velocity through the piping network. It corresponds to the equivalent height that a fluid would have to fall under gravity to attain that specific velocity. In many standard industrial and water supply piping system calculations, the change in fluid velocity between the suction and discharge points is minimal enough that the net velocity head is exceptionally small and can be completely neglected in routine manual calculations.

Pressure Head (h_p)

The **pressure head** is the energy equivalent height required by the pump to distribute water properly at the desired terminal pressure of the system. It represents the work needed to overcome any existing pressure differentials between closed containment vessels or to deliver fluid at a specific structural line pressure. For example, a benchmark engineering conversion to remember for board examinations is that a fluid pressure of **60 psi** is structurally equivalent to a pressure head of **138.5 feet** of water.

Friction Head (h_L)

The **friction head** is the energy loss associated with the continuous decrease in fluid pressure due to mechanical friction generated when the fluid flows along the internal walls of the pipes, as well as turbulent resistance through valves, elbows, tees, and system fittings. Friction head always works against the direction of fluid travel and must be directly compensated for by adding it to the required pump energy.

Pipe Friction Head Loss and Fluid Dynamics

The overall head loss (H_L) in a piping network consists of major losses due to boundary layer skin friction along straight sections of pipe (h_f) and minor losses (h_l) caused by structural disruptions like expansions, contractions, bends, valves, and fittings.

The total cumulative pipeline loss (H_L) is calculated as:

$$H_L = h_f + h_l$$

$$H_L = h_f + (h_c + h_e + h_g + h_b)$$

Major Losses, h_f and the Darcy-Weisbach Equation

Major losses are uniform losses along the pipe surface that remain consistent as long as the pipe cross-section, roughness, and material type do not change. The definitive model used to calculate this friction loss is the **Darcy-Weisbach Equation**:

$$h_f = f \frac{L}{D} \frac{v^2}{2g_o}$$

Where: h_f = Major friction head loss, measured in meters (m).
 f = Dimensionless resistance coefficient or Darcy friction factor. If specific charts or tables are omitted from an examination problem, standard convention dictates using a default value of $f = 0.02$.
 L = Total linear pipe length, including valves and fittings equivalent lengths (m).
 D = Internal diameter of the pipe conduit (m).
 v = Average fluid velocity inside the pipe channel (m/s).
 g_o = Observed local acceleration due to gravity (m/s^2).

Flow Characterization via Reynolds Number (R_e)

To determine if the fluid flow regime within a closed conduit is laminar or turbulent, engineers evaluate the dimensionless **Reynolds Number (R_e)**, first discovered by Osborne Reynolds in 1883. It represents the ratio of inertial forces to viscous forces within the fluid stream:

$$R_e = \frac{D v \rho}{\mu}$$

Where: ρ = Density of the fluid (kg/m^3).
 μ = Dynamic or absolute viscosity of the fluid, measured in Pascal-seconds (Pa-s) or Poise. The unit conversion factor is 1 poise = 1 dyne-s/cm²

By substituting **Kinematic Viscosity (ν)**, which is defined as dynamic viscosity divided by fluid density ($\nu = \frac{\mu}{\rho}$), the Reynolds number simplifies to:

$$R_e = \frac{D v}{\nu}$$

Where ν is quantified in square meters per second (m^2/s). The English engineering system conversion for kinematic viscosity is 1 stroke = 1cm²/sec.

Friction Factor Determination

The flow profile changes completely based on the magnitude of the calculated Reynolds number:

- **Laminar Flow Regime ($R_e \leq 2,000$):** The fluid moves in parallel sheets without mixing. Under this streamlined condition, the friction factor (f) depends solely on the Reynolds number and is calculated directly using the linear Hagen-Poiseuille relationship:

$$f = \frac{64}{R_e}$$

- **Turbulent Flow Regime ($R_e \geq 3,000$):** The fluid flow becomes chaotic and highly mixed. Here, the friction factor (f) becomes an intricate function of both the Reynolds number and the **Relative Roughness** of the pipe interior $\left(\frac{\varepsilon}{D}\right)$, where ε represents the absolute internal surface irregularities:

$$f = f\left(R_e, \frac{\varepsilon}{D}\right)$$

Minor Losses (h_l)

Minor losses stem from localized turbulences that dissipate energy when fluid encounters geometric transitions or control elements.

$$h_l = \sum k_L \frac{v^2}{2g_o}$$

Where k_L is the loss coefficient for contraction, enlargement, gate, valves, fittings and bends.

The values of k_L (if not given) can be found in published tables. The total losses, H_L , in a pipeline are the sum of the major and minor losses:

$$H_L = h_f + h_l$$

$$H_L = h_f + (h_c + h_e + h_g + h_b)$$

Where:

- **Contraction Losses (h_c):** Energy lost when the pipe diameter narrows.
- **Enlargement Losses (h_e):** Energy lost when the pipe suddenly expands.
- **Obstruction Losses (h_g):** Energy lost through internal restrictions like valves and gates.
- **Bend/Curve Losses (h_b):** Energy lost due to flow separation around elbows and curves.

The Pump Affinity Laws

The **Pump Affinity Laws** are a set of mathematical relationships that express the performance variations of a centrifugal pump when its operational speed (N) or its impeller diameter (D) is altered. These laws allow engineers to predict initial performance changes under the strict assumption that the pump's hydraulic efficiency remains constant across both operating conditions. In these equations, subscript 1 denotes the initial baseline condition, and subscript 2 denotes the modified, new condition.

Case 1: Constant Impeller Diameter ($D_1 = D_2$)

When the physical size of the impeller is held constant and only the rotational speed (N) of the shaft is modified, performance parameters scale as follows:

- **Capacity (Q):** Volumetric capacity varies directly with the first power of the pump speed.

$$\frac{Q_1}{Q_2} = \frac{N_1}{N_2}$$

- **Head (H):** Total dynamic head varies directly with the square of the pump speed.

$$\frac{H_1}{H_2} = \left(\frac{N_1}{N_2} \right)^2$$

- **Brake Power (BHP):** Brake horsepower varies directly with the cube of the pump speed.

$$\frac{BHP_1}{BHP_2} = \left(\frac{N_1}{N_2} \right)^3$$

Case 2: Constant Speed ($N_1 = N_2$)

When the rotational speed is held constant and the physical impeller diameter (D) is modified (such as when trimming an impeller to match a specific system demand), performance parameters scale as follows:

- **Capacity (Q):** Volumetric capacity varies directly with the first power of the impeller diameter.

$$\frac{Q_1}{Q_2} = \frac{D_1}{D_2}$$

- **Head (H):** Total dynamic head varies directly with the square of the impeller diameter.

$$\frac{H_1}{H_2} = \left(\frac{D_1}{D_2} \right)^2$$

- **Brake Power (BHP):** Brake horsepower varies directly with the cube of the impeller diameter.

$$\frac{BHP_1}{BHP_2} = \left(\frac{D_1}{D_2} \right)^3$$

Operational Variables and Units

When executing calculations using the affinity laws, the variable units must be consistently matched:


- **Q** = Capacity, measured in gallons per minute (gpm).
- **H** = Total head, measured in feet (ft).
- **BHP** = Brake horsepower, measured in horsepower (hp).
- **N** = Pump rotational speed, measured in revolutions per minute (rpm).

Pump Installation Configurations: Series vs. Parallel

When a single pump cannot fulfill system requirements, multiple pumps can be integrated into the network. The choice between a series or parallel configuration depends on whether the system needs a boost in pressure or an increase in volumetric capacity.

1. Pumps in Series (Staging for High Head)

Pumps in series are installed by directing the discharge line of the first pump straight into the suction inlet of the second pump. This configuration is structurally identical to the internal staging of a multi-stage pump.




- **Hydraulic Behavior:** When operating in series, the volumetric capacity (Q) passing through both pumps remains constant, while the total dynamic head (TDH) increases cumulatively at that given capacity.
- **Performance Characteristic:**

$$Q_{Total} = Q_1 = Q_2$$
$$H_{Total} = H_1 + H_2$$

- **Application Profile:** This layout is used for high-resistance systems where fluid must be transported across significant vertical elevations or into high-pressure containment vessels.

2. Pumps in Parallel (Network Scaling for High Capacity)

Pumps in parallel are installed by connecting the suction inlets of both pumps to a shared source line and combining their individual discharge lines into a single, common header manifold.



- **Hydraulic Behavior:** When operating in parallel, both units work against the same total dynamic head (TDH), while the overall volumetric system capacity (Q) is doubled (assuming identical pump models).

- **Performance Characteristic:**

$$Q_{Total} = Q_1 + Q_2$$
$$H_{Total} = H_1 = H_2$$

- **Application Profile:** This layout is used for systems with variable flow demands, allowing operators to activate additional pumps during peak flow requirements without modifying system pressure limits.

Net Positive Suction Head (NPSH) and Cavitation Control

In industrial hydraulics and fluid machinery design, safeguarding a pump from mechanical degradation requires a strict thermodynamic evaluation of the suction line. **Net Positive Suction Head (NPSH)** serves as a critical engineering index that defines the absolute pressure margin required at the pump inlet to ensure the fluid remains in a stable liquid phase and operates smoothly without encountering cavitation.

The Phenomenon of Cavitation

Cavitation is a highly destructive hydraulic phenomenon that occurs when the local static pressure at any point inside the pump—typically at the low-pressure zone near the eye of the impeller—drops below the vapor pressure corresponding to the operating temperature of the liquid. When this localized pressure threshold is breached, the liquid reaches its boiling threshold at ambient temperature, causing it to vaporize and form millions of microscopic vapor bubbles.



As these vapor bubbles are swept along by the rotating impeller blades into regions of higher static pressure within the volute casing, they become unstable. The surrounding high pressure forces the bubbles to abruptly collapse or implode violently at the metal surfaces of the impeller. These microscopic implosions generate extreme localized shockwaves and high-velocity micro-jets that repeatedly strike the pump material. Over time, this mechanical pounding induces severe fatigue, leading to pitting, erosion, and structural failure of the impeller and casing. Operationally, cavitation manifests as severe system vibrations, a distinct crackling noise resembling the pumping of gravel, a sharp drop in pump efficiency, and a sudden loss of discharge capacity.

Understanding NPSH Frameworks: Required vs. Available

To mathematically evaluate and prevent cavitation, engineers classify NPSH into two separate, independent metrics that must be balanced.

1. Net Positive Suction Head Required (NPSH_r)

The **Required Net Positive Suction Head (NPSH_r)** is a minimum pressure threshold that is experimentally determined and provided by the pump manufacturer. It is a strict function of the internal pump design, including impeller geometry, vane profiling, and rotational speed. NPSH_r represents the internal pressure drop that the fluid experiences as it enters the suction nozzle and moves into the impeller eye; consequently, it is the absolute minimum energy the incoming fluid must possess to avoid boiling inside the pump.

2. Net Positive Suction Head Available (NPSH_a)

The **Available Net Positive Suction Head (NPSH_a)** is a hydraulic profile determined directly by the plant designer during the design and proposed installation phase of the pumping network. It is a function of the external system piping layout, fluid temperature, atmospheric conditions, and elevation. NPSH_a measures the actual net useful pressure head present at the pump's suction inlet flange.

To successfully **avoid cavitation** during operation, the hydraulic design must always satisfy the following strict inequality:

$$\text{NPSH}_a \geq \text{NPSH}_r$$

Engineering Remediation Strategies

If a field calculation or diagnostic test reveals that $\text{NPSH}_a < \text{NPSH}_r$, the system will undergo heavy cavitation. To correct this deficit, plant engineers have two primary modifications available depending on whether the system is constrained by layout or equipment selections:

1. **Modify the Plant Layout (Increase Suction Pressure):** The designer can physically decrease the static suction lift by changing the plant layout and raising the elevation of the supply source relative to the pump, or by lowering the pump closer to the water level. This directly reduces the hydraulic pull required, boosting NPSH_a .
2. **Modify Pump Operation (Reduce Demand Head):** Alternatively, engineers can reduce the effective suction head requirements by using pumps with a larger physical capacity but operating them at partial loads or lower rotational speeds. Throttling the operational speed lowers the velocity and internal turbulence at the impeller eye, which effectively drops the manufacturer's required NPSH_r threshold to match the system's constraints.

Mathematical Evaluation of NPSH_a

The absolute available suction head is quantified using the governing engineering relationship:

$$\text{NPSH}_a = h_p \pm h_{SL} - h_v - h_L$$

Where all parameters are evaluated as equivalent heads in units of length (typically meters or feet):

- h_p = Absolute pressure head acting on the free surface of the liquid supply source. When the source tank is vented or open to the atmosphere, this matches the local atmospheric pressure corresponding to its geographical altitude.
- h_{SL} = Static height of the liquid surface relative to the pump centerline. This value changes sign based on the system geometry:
 - **Positive (+ h_{SL}):** Designated as positive when a **static suction head** (flooded suction) is present, meaning the liquid supply level is located *above* the pump centerline.
 - **Negative (- h_{SL}):** Designated as negative when a **static suction lift** is present, meaning the liquid supply level is located *below* the pump centerline.
- h_v = Vapor pressure head corresponding directly to the temperature of the liquid at the suction zone. This thermodynamic property determines the fluid's boiling point and can be determined accurately using standard engineering steam tables.
- h_L = Total head loss accumulated across the suction line due to fluid friction against the pipe walls and turbulent restrictions within elbows, foot valves, and strainers.

Pump Efficiency (η_p)

In real-world applications, a pump cannot convert 100% of its incoming mechanical shaft power into hydraulic energy due to internal fluid friction, mechanical friction in the bearings and seals, and volumetric leakage past the wear rings. Therefore, mechanical systems must be evaluated using **Pump Efficiency** (η_p).

Pump efficiency is defined as the dimensionless ratio of the useful output power over the total input power delivered to the pump shaft. Specifically, it compares the **Water Power (WP)** or hydraulic power output successfully added to the fluid against the **Brake Power (BP)** input supplied by the driving motor to the pump coupling. Expressed as a percentage, the governing formula is written as:

$$\eta_p = \frac{WP}{BP} * 100\%$$

- **Water Power (WP)** is the calculated hydraulic energy rate imparted directly to the liquid medium.
- **Brake Power (BP)** is the actual mechanical brake horsepower or kilowatt input required from the electric motor or engine shaft to keep the pump operating at its design point. Because of internal energy losses, BP will always be greater than WP, ensuring the calculated efficiency remains below 100%

Pump Specific Speed (N_s)

In turbomachinery and hydraulic engineering, **Pump Specific Speed (N_s)** is a fundamental parameter used to characterize and describe the hydraulic design and operational features of centrifugal pumps. It functions as a geometric index that classifies pump impellers based on their performance profile and proportions rather than their physical size.

Formally, specific speed is defined as the rotational speed in revolutions per minute at which a given geometrically similar impeller would operate if it were scaled down proportionally in size so as to deliver a standard rated capacity of **1 gallon per minute (gpm)** against a total dynamic head of **1 foot**.

The Specific Speed Equation

The mathematical formula used to compute the specific speed of a pump is expressed as follows:

$$N_s = \frac{N\sqrt{Q}}{H^{3/4}}$$

Where:

- N_s = Specific speed of the pump, conventionally noted with units of revolutions per minute (rpm).
- N = Impeller rotational speed, measured in revolutions per minute (rpm).
- Q = Flow capacity of the pump, measured strictly in gallons per minute (gpm).
- H = Pump head per stage, measured strictly in feet (ft).

Crucial Special Conditions and Corrections

Meticulous attention must be paid to the physical configuration of the pump inlet and staging. The variables Q and H used in the equation must reflect the performance of a **single impeller eye working across a single stage**:

1. Double Suction Pumps (Inlet Correction)

A double suction pump features an impeller design where fluid enters from both sides simultaneously, effectively splitting the total incoming volumetric load. For a **double suction pump**, the total capacity Q must be **divided by 2** before substituting it into the formula $\left(Q_{actual} = \frac{Q_{total}}{2}\right)$. This isolation accurately accounts for the flow profile experienced by a single side of the impeller eye.

2. Multi-Stage Pumps (Pressure/Head Correction)


A multi-stage pump consists of multiple impellers mounted in series along a single shaft to successively boost discharge pressure. Because the total head is a cumulative build-up across all stages, for **multi-stage pumps**, the total dynamic head H must be **divided by the number of stages** $\left(H_{actual} = \frac{H_{total}}{2}\right)$. This ensures the value represents the net head generated per individual stage.

Fluid Behavior in Integrated Piping Networks

When pipes of different configurations connect multiple reservoirs, fluid parameters adjust according to the physical path layout.

1. Pipes of Different Diameters in Series

When components are arranged sequentially in a series network, the fluid must pass through each section one after another.



- **Volumetric Flow Capacity:** Because the fluid is contained within a single continuous loop, the volumetric flow rate (Q) remains identical across all connected sections:


$$Q = Q_1 = Q_2 = Q_3$$

- **Total Network Head Loss:** The total head loss (H_L) across the entire series system is the cumulative sum of individual friction and minor losses within each component:

$$H_L = h_{f1} + h_{f2} + h_{f3}$$

2. Pipes Connected in Parallel

When a single pipeline branches at a junction into multiple parallel lines before recombining downstream, the fluid load splits across the separate paths.



- **Volumetric Flow Capacity:** The total volumetric flow rate (Q_{total} or Q_1) entering the junction must equal the sum of the individual flow rates passing through the parallel branches:

$$Q_1 = Q_2 + Q_3$$

$$Q_1 = Q_4$$

- **Total Network Head Loss:** Because each parallel path connects the exact same two common junctions, the energy drop across each separate path must be identical, regardless of its length or diameter:

$$H_L = h_{f1} + h_{f2} + h_{f3}$$

Where: $h_{f2} = h_{f3}$

Reciprocating Pumps

Reciprocating pumps are positive displacement machines that rely on the mechanical movement of a piston within a closed cylinder to move fluid via alternating suction and discharge strokes.

1. Piston Displacement (V_D)

Piston displacement represents the theoretical volumetric rate swept by the piston during its operation. This mathematical calculation is split depending on whether the volume of the piston rod is neglected or considered:

- **Neglecting Piston Rod:** When the small volume of the operating rod is omitted from the calculation, the general formulation for displacement is:

$$V_D = \left[\frac{\pi}{4} D^2 \right] L \left[\frac{c \cdot a \cdot (n/60) \cdot 2}{s} \right]$$

Where $s=2$ for pumps and compressors, $c=1$, and $a=2$. Substituting these standard system coefficients simplifies the direct theoretical displacement equation to:

$$V_D = 2 \left[\frac{\pi}{4} D^2 L N \right]$$

Where D is the cylinder internal diameter, L is the piston stroke length, and N is the rotational speed in revolutions per minute.

- **Considering Piston Rod:** When the physical volume of the piston rod (diameter d) is included, it reduces the effective area on the crank side of the cylinder during the stroke. The modified volumetric displacement formulation becomes:

$$V_D = \frac{\pi}{4} D^2 L N + \frac{\pi}{4} (D^2 - d^2) L N$$

2. Pump Slip and Percent Slip

In real-world operations, the actual volumetric flow rate (Q) delivered by a reciprocating pump is typically less than the theoretical piston displacement (V_D) due to internal fluid leakage past the piston seals and lagging valve closures. This metric variance is called **Slip**:

$$Slip = V_D - Q$$

To express this value as a normalized engineering ratio, **Percent Slip** is calculated using the following equation:

$$\%Slip = 1 - \frac{Q}{V_D}$$

3. Volumetric Efficiency (η_v)

Volumetric efficiency measures the effectiveness of a positive displacement pump in matching its theoretical displacement capacity. It can be calculated directly from the slip value or derived using internal clearance volume ratios (c) and fluid volume boundaries (V_1 and V_2):

$$\eta_v = 1 - \text{slip}$$

$$\eta_v = \frac{Q}{V_d} = 1 + c - c\left(\frac{V_1}{V_2}\right)$$